

**NSF / ANSI Standard 58 - Reverse Osmosis Drinking Water Treatment Systems**  
Authorized Registered Formulation

**Customer Name:** Alpspring Inc.

**Facility Location:** Taiwan

**Customer Number:** 4K450

**Facility At:** Hsinchu County, Taiwan

**Facility Number:** 4K451

---

**Component Trade Name(s):** NF90-2012-180  
NF90-1812-100  
NF90-1812-60  
XLE-2012-125  
XLE-1812-75  
TW40-2012-100  
TW40-1812-50

---





# TEST REPORT

Send To: 4K450  
Alpspring Inc.  
No. 5 Gongye 4th Road  
Hukou Shiang  
Hsinchu County 303  
Taiwan  
Attn: Mr. Frank Ho

Customer: 4K450  
Alpspring Inc.  
No. 5 Gongye 4th Road  
Hukou Shiang  
Hsinchu County 303  
Taiwan  
Attn: Mr. Frank Ho


Plant: 4K451  
Alpspring Inc.  
No. 5 Gongye 4th Road  
Hukou Shiang  
Hsinchu County 303  
Taiwan  
Attn: Mr. Frank Ho

Sample Description: COMPONENT-RO MEMBRANE  
Test Type: QQ - Qualification Testing

Thank you for having your product tested by NSF.

The enclosed report details the result of the testing performed on your product. Your program representative will be contacting you in the near future if there are any remaining issues concerning the status of this product.

Please do not hesitate to contact us if you have any immediate questions pertaining to your product.

Reviewer:   
McLellan, Clif - Director, Toxicology Services

Status: **Pass**

CC: Program: 0020 - Drinking Water Treatment Units  
Program Rep: Xiaobing Yuan  
Region: 03 - Asia  
PA Project: 9009714

**General Information**

Standard: 58 - 2009 - REVERSE OSMOSIS DRINKING WATER TREATMENT SYSTEMS

DCC Number / Tracking ID: PW04301  
Flushing Time: 24 hours  
Model Number: NF90-2012-180Sample Id: **S-0000735397**  
Description: NF90-2012-180  
Sampled Date: 03/04/2010  
Received Date: 03/04/2010

Testing Parameter	Sample	Control	Result	Units
<b>Chemistry Lab</b>				
* Static Extraction Test Data Sheet				
Samples tested with media	No			
Samples tested without media	Yes			
Number of units exposed with media	0			
Number of units exposed without media	1			
All connections supplied by mfr.	No			
Complete flushing instructions provided	Yes			
Flushing procedure description	The membrane was flushed for 24 hours prior to exposure.			
Water temperature	22.3		22.3	degrees C
Does media comply with mfg. claims	N/A			
Static Extraction Testing	Complete			
* Chlorine, Free				
Chlorine, Free Available	ND(0.05)		ND(0.05)	mg/L
Solids, Total Dissolved, (180C), SM 2540C				
Solids, Total Dissolved	53		53	mg/L
* Water pH				
pH	6.57		6.57	

Sample Id: **S-0000735398**  
Description: Final Composite Sample w/o Media  
Sampled Date: 03/24/2010  
Received Date: 03/04/2010

Testing Parameter	Sample	Control	Result	Units
<b>Chemistry Lab</b>				
Polynuclear Aromatic Hydrocarbons by GCMS				
Acenaphthene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Acenaphthylene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Anthracene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Benzo(a)Anthracene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Benzo(a)Pyrene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Benzo(b)Fluoranthene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Benzo(g,h,i)Perylene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Benzo(k)Fluoranthene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Chrysene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L

Sample Id: **S-0000735398**

Testing Parameter	Sample	Control	Result	Units
<b>Chemistry Lab ( Cont'd )</b>				
Dibenzo(a,h)Anthracene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Fluoranthene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Fluorene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Indeno(1,2,3,-c,d)Pyrene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Naphthalene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Phenanthrene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Pyrene	ND(0.1)	ND(0.1)	ND(0.1)	ug/L
Adipic Acid by LCMS				
Adipic Acid	ND(100)	ND(100)	ND(100)	ug/L
Semivolatile Compounds, Base/Neutral/Acid 625 Scan, Data Workup				
No Compounds Detected	ND(4)	Complete	ND(4)	ug/L
Semivolatile Compounds, Base/Neutral/Acid Target 625, Data Workup				
N-Nitrosodimethylamine	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosomethylethylamine	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosodiethylamine	ND(4)	ND(4)	ND(4)	ug/L
1-Methoxy-2-propanol acetate	ND(4)	ND(4)	ND(4)	ug/L
Cyclohexanone	ND(4)	ND(4)	ND(4)	ug/L
Phenol	ND(4)	ND(4)	ND(4)	ug/L
Aniline	ND(4)	ND(4)	ND(4)	ug/L
2-Chlorophenol	ND(4)	ND(4)	ND(4)	ug/L
3-Cyclohexene-1-carbonitrile	ND(4)	ND(4)	ND(4)	ug/L
2-Ethyl-1-hexanol	ND(4)	ND(4)	ND(4)	ug/L
Benzenemethanol (Benzylalcohol)	ND(4)	ND(4)	ND(4)	ug/L
2-Methylphenol (o-Cresol)	ND(4)	ND(4)	ND(4)	ug/L
4-Methylphenol (p-Cresol)	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosopyrrolidine	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosodi-n-propylamine	ND(4)	ND(4)	ND(4)	ug/L
1-Phenylethanone (Acetophenone)	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosomorpholine	ND(4)	ND(4)	ND(4)	ug/L
2-Phenyl-2-propanol	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosopiperidine	ND(4)	ND(4)	ND(4)	ug/L
Triethylphosphate	ND(4)	ND(4)	ND(4)	ug/L
Isophorone	ND(4)	ND(4)	ND(4)	ug/L
2,4-Dimethylphenol	ND(4)	ND(4)	ND(4)	ug/L
Naphthalene	ND(4)	ND(4)	ND(4)	ug/L
Benzothiazole	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosodi-n-butylamine	ND(4)	ND(4)	ND(4)	ug/L
p-tert-Butylphenol	ND(4)	ND(4)	ND(4)	ug/L
2-Methylnaphthalene	ND(4)	ND(4)	ND(4)	ug/L
1(3H)-Isobenzofuranone	ND(4)	ND(4)	ND(4)	ug/L
a,a-Dimethyl-p-isopropylbenzenemethanol	ND(4)	ND(4)	ND(4)	ug/L
1,1'-(1,3-Phenylene)bis ethanone	ND(4)	ND(4)	ND(4)	ug/L
Dimethylphthalate	ND(4)	ND(4)	ND(4)	ug/L

Sample Id: **S-0000735398**

Testing Parameter	Sample	Control	Result	Units
<b>Chemistry Lab ( Cont'd )</b>				
1,1'-(1,4-Phenylene)bis ethanone	ND(4)	ND(4)	ND(4)	ug/L
aaa'a Tetramethyl-1,3-benzenedimethanol	ND(4)	ND(4)	ND(4)	ug/L
Acenaphthylene	ND(4)	ND(4)	ND(4)	ug/L
aaa'a Tetramethyl-1,4-benzenedimethanol	ND(4)	ND(4)	ND(4)	ug/L
2,4-Di-tert-butylphenol	ND(4)	ND(4)	ND(4)	ug/L
Dimethyl terephthalate	ND(4)	ND(4)	ND(4)	ug/L
Acenaphthene	ND(4)	ND(4)	ND(4)	ug/L
Ethyl-4-ethoxybenzoate	ND(4)	ND(4)	ND(4)	ug/L
p-tert-Octylphenol	ND(4)	ND(4)	ND(4)	ug/L
Diethylphthalate	ND(4)	ND(4)	ND(4)	ug/L
Fluorene	ND(4)	ND(4)	ND(4)	ug/L
N-Nitrosodiphenylamine	ND(4)	ND(4)	ND(4)	ug/L
Phenanthrene	ND(4)	ND(4)	ND(4)	ug/L
Anthracene	ND(4)	ND(4)	ND(4)	ug/L
Di-n-butylphthalate	ND(4)	ND(4)	ND(4)	ug/L
Fluoranthene	ND(4)	ND(4)	ND(4)	ug/L
Pyrene	ND(4)	ND(4)	ND(4)	ug/L
Butylbenzylphthalate	ND(4)	ND(4)	ND(4)	ug/L
Benzo(a)anthracene	ND(4)	ND(4)	ND(4)	ug/L
bis(2-Ethylhexyl)phthalate	ND(4)	ND(4)	ND(4)	ug/L
bis(2-Ethylhexyl)adipate	ND(4)	ND(4)	ND(4)	ug/L
Chrysene	ND(4)	ND(4)	ND(4)	ug/L
Di-n-octylphthalate	ND(4)	ND(4)	ND(4)	ug/L
Benzo(b)fluoranthene	ND(4)	ND(4)	ND(4)	ug/L
Benzo(k)fluoranthene	ND(4)	ND(4)	ND(4)	ug/L
Benzo(a)pyrene	ND(4)	ND(4)	ND(4)	ug/L
Dibenzo(a,h)anthracene	ND(4)	ND(4)	ND(4)	ug/L
Indeno(1,2,3-cd)pyrene	ND(4)	ND(4)	ND(4)	ug/L
Benzo(g,h,i)perylene	ND(4)	ND(4)	ND(4)	ug/L
Total Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)				
Arsenic	ND(1)	ND(1)	ND(1)	ug/L
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)				
Barium	ND(1)	2	ND(1)	ug/L
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)				
Beryllium	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)				
Cadmium	ND(0.2)	ND(0.2)	ND(0.2)	ug/L
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)				
Chromium	ND(1)	ND(1)	ND(1)	ug/L
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)				
Copper	ND(1)	7	ND(1)	ug/L
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)				
Mercury	ND(0.2)	ND(0.2)	ND(0.2)	ug/L

Sample Id: **S-0000735398**

Testing Parameter	Sample	Control	Result	Units
<b>Chemistry Lab ( Cont'd )</b>				
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)				
Lead	ND(1)	ND(1)	ND(1)	ug/L
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)				
Antimony	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)				
Selenium	ND(2)	ND(2)	ND(2)	ug/L
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)				
Thallium	ND(0.2)	ND(0.2)	ND(0.2)	ug/L
Carbon, Total Organic, SM 5310C, in Water				
Total Organic Carbon	0.3	0.4	ND(0.1)	mg/L
Date Analyzed	29-MAR-2010			
* Epichlorohydrin (Modified EPA 524.2)				
Epichlorohydrin	ND(5)	ND(5)	ND(5)	ug/L
* 1,3-Butadiene (Modified EPA 524.2)				
1,3-Butadiene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
* 1,3-Dichloro-2-propanol in water, GC/FID				
1,3-Dichloro-2-propanol	ND(20)	ND(20)	ND(20)	ug/L
* Acrylonitrile, EPA 524.2				
Acrylonitrile	0.2	ND(0.2)	0.2	ug/L
* Benzyl alcohol				
Benzyl Alcohol	ND(50)	ND(50)	ND(50)	ug/L
* Bisphenol A - propylene oxide adducts, LC/UV				
Bisphenol A diglycideryl ether	ND(20)	ND(20)	ND(20)	ug/L
Bisphenol A propoxylate	ND(20)	ND(20)	ND(20)	ug/L
Bisphenol A diglycidyl ether	ND(20)	ND(20)	ND(20)	ug/L
* Bisphenol A, LC/UV				
Bisphenol A	ND(10)	ND(10)	ND(10)	ug/L
* 1,2-Dichloro-3-propanol in Water, GC/FID				
1,2-Dichloro-3-Propanol	ND(20)	ND(20)	ND(20)	ug/L
* 4,4'-Dichlorodiphenyl sulfone by LC/UV				
4,4'-Dichlorodiphenyl sulfone	ND(20)	ND(20)	ND(20)	ug/L
* Dimethylformamide, LC/UV				
Dimethylformamide	16	ND(5)	16	ug/L
* Dioxane, 1,4-, P&T GC/MS				
1,4-Dioxane	ND(5)	ND(5)	ND(5)	ug/L
* Ethylene glycol, LC/MS				
Ethylene glycol	ND(200)	ND(200)	ND(200)	ug/L
* Isophthalic acid, LC/UV				
Isophthalic acid	ND(30)	ND(30)	ND(30)	ug/L
* Maleic Acid, LC/UV				
Maleic Acid	ND(10)	ND(10)	ND(10)	ug/L
* Methylenedianiline Micro/derivatization GC/ECD				
2,4'-Methylenedianiline	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
4,4'-Methylenedianiline	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
2,2'-Methylenedianiline	ND(0.5)	ND(0.5)	ND(0.5)	ug/L

Sample Id: S-0000735398

Testing Parameter	Sample	Control	Result	Units
<b>Chemistry Lab ( Cont'd )</b>				
* Phenylene diamine, m-, LC/UV				
m-Phenylene diamine	ND(50)	ND(50)	ND(50)	ug/L
* Phthalic Acid, LC/UV				
Phthalic Acid	ND(10)	ND(10)	ND(10)	ug/L
* Terephthalic acid, LC/UV				
Terephthalic acid	ND(50)	ND(50)	ND(50)	ug/L
* Triethanolamine by NSF Method				
Triethanolamine	ND(50)	ND(50)	ND(50)	ug/L
* 1,3,5-cyclohexane tricarboxylic acid, by HPLC - UV				
1,3,5-Cyclohexane tricarboxylic acid	ND(0.5)	Complete	ND(0.5)	mg/L
* Chlorobenzendiamine isomers, derivatization GC/ECD				
4-chloro-1,2-phenylene diamine	ND(1)	ND(1)	ND(1)	ug/L
4-chloro-1,3-phenylene diamine	1	ND(1)	1	ug/L
2-chloro-1,4-phenylene diamine	ND(1)	ND(1)	ND(1)	ug/L
Volatile Organic Compounds (Ref: EPA 524.2)				
Dichlorodifluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Chloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Vinyl Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Bromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Chloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Trichlorofluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Trichlorotrifluoroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Methylene Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,1-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
trans-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,1-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
2,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
cis-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Chloroform	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Bromochloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,1,1-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,1-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Carbon Tetrachloride	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Trichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Bromodichloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Dibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
cis-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
trans-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,1,2-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,3-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Tetrachloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L

Sample Id: S-0000735398

Testing Parameter	Sample	Control	Result	Units
<b>Chemistry Lab ( Cont'd )</b>				
Chlorodibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Chlorobenzene	1.0	ND(0.5)	1.0	ug/L
1,1,1,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Bromoform	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,1,2,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2,3-Trichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,3-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,4-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Carbon Disulfide	ND(1)	ND(1)	ND(1)	ug/L
Methyl-tert-Butyl Ether (MTBE)	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
tert-Butyl ethyl ether	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Methyl Ethyl Ketone	ND(5)	ND(5)	ND(5)	ug/L
Methyl Isobutyl Ketone	ND(5)	ND(5)	ND(5)	ug/L
Toluene	3.6	ND(0.5)	3.6	ug/L
Ethyl Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
m+p-Xylenes	ND(1)	ND(1)	ND(1)	ug/L
o-Xylene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Styrene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Isopropylbenzene (Cumene)	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
n-Propylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Bromobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
2-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
4-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,3,5-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
tert-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2,4-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
sec-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
p-Isopropyltoluene (Cymene)	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2,3-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
n-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2,4-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Hexachlorobutadiene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
1,2,3-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Naphthalene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Total Trihalomethanes	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
Total Xylenes	ND(0.5)	ND(0.5)	ND(0.5)	ug/L
* Water pH				
pH	6.02	6.57	ND(0.01)	



---

**Job Notes:**

Initial Qualification (Sample #2) of Alpspring Inc.'s NF90-2012-180. cp 4/16/10

**Job Attachments:**



Test Configuration

**Testing Laboratories:**

All work performed at: _____	<table border="0"> <tr> <td style="border-bottom: 1px dashed black; padding-bottom: 2px;">Id</td> <td style="border-bottom: 1px dashed black; padding-bottom: 2px;">Address</td> </tr> <tr> <td style="padding: 2px;">NSF_AA</td> <td style="padding: 2px;">NSF International 789 N. Dixboro Road Ann Arbor MI 48105</td> </tr> </table>	Id	Address	NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105
Id	Address				
NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105				

**References to Testing Procedures:**

NSF Reference	Parameter / Test Description
C0011	* Static Extraction Test Data Sheet
C0019	* Chlorine, Free
C0314	Polynuclear Aromatic Hydrocarbons by GCMS
C0556	Adipic Acid by LCMS
C2023	Semivolatile Compounds, Base/Neutral/Acid 625 Scan, Data Workup
C2024	Semivolatile Compounds, Base/Neutral/Acid Target 625, Data Workup
C3035	Total Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3038	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3041	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3046	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3052	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3058	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3071	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3100	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3113	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3115	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3127	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3165	Carbon, Total Organic, SM 5310C, in Water
C3364	* Epichlorohydrin (Modified EPA 524.2)
C3369	* 1,3-Butadiene (Modified EPA 524.2)
C4004	* 1,3-Dichloro-2-propanol in water, GC/FID
C4024	* Acrylonitrile, EPA 524.2
C4050	* Benzyl alcohol
C4056	* Bisphenol A - propylene oxide adducts, LC/UV
C4057	* Bisphenol A, LC/UV
C4114	* 1,2-Dichloro-3-propanol in Water, GC/FID
C4115	* 4,4'-Dichlorodiphenyl sulfone by LC/UV
C4134	* Dimethylformamide, LC/UV
C4137	* Dioxane, 1,4-, P&T GC/MS
C4168	* Ethylene glycol, LC/MS
C4227	* Isophthalic acid, LC/UV
C4263	* Maleic Acid, LC/UV
C4283	* Methylenedianiline Micro/derivatization GC/ECD
C4318	* Phenylene diamine, m-, LC/UV
C4322	* Phthalic Acid, LC/UV
C4357	* Terephthalic acid, LC/UV
C4376	* Triethanolamine by NSF Method
C4427	* 1,3,5-cyclohexane tricarboxylic acid, by HPLC - UV
C4457	Solids, Total Dissolved, (180C), SM 2540C
C4515	* Chlorobenzendiamine isomers, derivatization GC/ECD
C4662	Volatile Organic Compounds (Ref: EPA 524.2)
C6408	* Water pH

Test descriptions preceded by an asterisk "\*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.