

PRECICA ENVIRONMENT CORPORATION

精準環境股份有限公司

3F.No.Ln16.77Xing' ai Rd., Neihu Dist.
Taipei City 114, Taiwan (R.O.C.)
TEL : 886-2-8791-1131 FAX : 886-2-8791-1876
EPA ACCREDITED LABORATORY

CERTIFICATE OF ANALYSIS

NAME OF APPLICANT : Deng Kang Technology Co.Ltd
SAMPLING SITE :
2F.,No.88-9,Sec. 1 ,Guangfu Rd., Sanchong City, Taipei, Taiwan

Report No. :EV12FH165
SAMPLING DATE : 11.JU.2012
REPORT DATE : 13.JU.2012
CONTACT PERSON :Tracy Kao

NAME OF SAMPLE ITEMS	REFUSE Raw water 3KG	REFUSE Ultra Filter3KG	Units	Remarks
Total Bacterial Count	55	<5	CFU/ml	MDL=5
Coliform Group	<1	<1	CFU/100ml	MDL=1
	Raw water 7KG	Ultra Filter7KG		
Total Bacterial Count	20	<5	CFU/ml	MDL=5
Coliform Group	<1	<1	CFU/100ml	MDL=1
	BLANK	BLANK		

REMARK :

I hereby certify that the results of the examination were as described above.



Tom Lu
Tom Lu Lab Director